


CERTIFICATE

Certified Passive House Component

Component-ID 0885wi03 valid until 31st December 2018

Passive House Institute
Dr. Wolfgang Feist
64283 Darmstadt
Germany




Category: **Window Frame**
Manufacturer: **FANZOLA SNC,
Rosta,
Italy**
Product name: **EVO NULL 68**

**This certificate was awarded based on the following
criteria for the cool, temperate climate zone**

Comfort $U_W = 0.79 \leq 0.80 \text{ W}/(\text{m}^2 \text{ K})$
 $U_{W,\text{installed}} \leq 0.85 \text{ W}/(\text{m}^2 \text{ K})$
with $U_g = 0.70 \text{ W}/(\text{m}^2 \text{ K})$

Hygiene $f_{Rsi=0.25} \geq 0.70$



cool, temperate climate



phA



**CERTIFIED
COMPONENT**

Passive House Institute

Passive House
efficiency class

phE


phD

phC


phB

phA

www.passivehouse.com



Calculation model



Isothermal

Description

Timberframe with installation frame of dense PIR-foam ($\lambda = 0.086 \text{ W/(mK)}$) and insulation of cork ($\lambda = 0,040 \text{ W/(mK)}$). Integrated drainage through installation system. Pane thickness: 49 mm (6,36/16/4/16/6,36), rebate depth: 18mm, spacer: Swisspacer ULTIMATE

Explanation





The window U-values were calculated for the test window size of $1.23 \text{ m} \times 1.48 \text{ m}$ with $U_g = 0.70 \text{ W/(m}^2 \text{ K)}$. If a higher quality glazing is used, the window U-values will improve as follows:

Glazing	$U_g =$	0.70	0.64	0.58	0.52	W/(m ² K)
		↓	↓	↓	↓	
Window	$U_W =$	0.79	0.74	0.70	0.65	W/(m ² K)

Transparent building components are classified into efficiency classes depending on the heat losses through the opaque part. The frame U-Values, frame widths, thermal bridges at the glazing edge, and the glazing edge lengths are included in these heat losses. A more detailed report of the calculations performed in the context of certification is available from the manufacturer.




The Passive House Institute has defined international component criteria for seven climate zones. In principle, components which have been certified for climate zones with higher requirements may also be used in climates with less stringent requirements. In a particular climate zone it may make sense to use a component of a higher thermal quality which has been certified for a climate zone with more stringent requirements.

Further information relating to certification can be found on www.passivehouse.com and passipedia.org.

Frame values			Frame width b_f mm	U -value frame U_f W/(m ² K)	Ψ -glass edge Ψ_g W/(m K)	Temp. Factor $f_{Rsi=0.25}$ [-]
Top	(to)		89	0.73	0.031	0.76
Side	(s)		89	0.73	0.031	0.76
Bottom	(bo)		92	0.72	0.032	0.76
Mullion flying	(fm)		136	0.79	0.029	0.74

Spacer: SWISSPACER Ultimate Secondary seal: Polysulfide

Validated installations

Insulated formwork blocks		Timber frame		EIFS	
$U_{Wall} = 0.15 \text{ W/(m}^2 \text{ K)}$		$U_{Wall} = 0.13 \text{ W/(m}^2 \text{ K)}$		$U_{Wall} = 0.13 \text{ W/(m}^2 \text{ K)}$	
					
$\Psi_{install}$	W/(m K)	$\Psi_{install}$	W/(m K)	$\Psi_{install}$	W/(m K)
Top	0.006	Top	0.020	Top	0.005
Side	0.006	Side	0.020	Side	0.005
Bottom	0.015	Bottom	0.026	Bottom	0.011
$U_{W, installed} = 0.81 \text{ W/(m}^2 \text{ K)}$		$U_{W, installed} = 0.85 \text{ W/(m}^2 \text{ K)}$		$U_{W, installed} = 0.81 \text{ W/(m}^2 \text{ K)}$	